

File Original and First Copy with
Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No.

Well tag id: ALT 200
29/2 — 4 E

(1) OWNER: Name PAUL WAKE Address LANCLEY P.O. Box 200 982

(2) LOCATION OF WELL: County Island — SW 1/4, N.W. Sec. 7 T. 29 N. R. 2 E. W. 1

Bearing and distance from section or subdivision corner 1600' W. C. V. 35° 46' 00" S. 46' 00" S. 46' 00" S. 46' 00" S.

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 6
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 280 ft. Depth of completed well 880 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 270 ft.
Threaded ☐ " Diam. from 0 ft. to 270 ft.
Welded ☒ " Diam. from 0 ft. to 270 ft.

Perforations: Yes ☐ No ☐

Type of perforator used COOK
SIZE of perforations 10 in. by 270 in.
perforations from 0 ft. to 270 ft.
perforations from 0 ft. to 270 ft.
perforations from 0 ft. to 270 ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK Model No. 270
Type 6 Slot size 10 from 270 ft. to 880 ft.
Diam. 6 Slot size 10 from 270 ft. to 880 ft.

Gravel packed: Yes ☐ No ☐ Size of gravel: 20 ft.
Gravel placed from 0 ft. to 270 ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.
Material used in seal Ben to 111
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name COOK
Type 6 H.P.

(8) WATER LEVELS: Land-surface elevation 220 ft.
Static level 270 ft. below top of well Date 9/12/82
Artesian pressure lbs. per square inch Date 9/12/82
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? COOK
Yield: gal/min. with ft. drawdown after hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level

Date of test 9/12/82
Bailer test 10 gal/min. with 5 ft. drawdown after 1 1/2 hrs.
Artesian flow g.p.m. Date 9/12/82
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, as show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
TOP SOIL	0	1
SAND + CLAY GRAY	1	65
SAND + GRAY	65	200
CLAY GRAY	200	240
SAND W.W. GRAY	240	280

Work started 9/1/82, 19 9/12/82 Completed 9/12/82, 19 9/12/82

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief.

NAME B+W DRILLING
(Person, firm, or corporation) (Type or print)

Address 4087 E. PRK. RD.

[Signed] John (Well Driller)

License No. 255 Date 9/12/82

WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No.

(1) OWNER: Name PAUL WAKE Address LANCLEY P.O. Box 200 98260
 (2) LOCATION OF WELL: County Island SW 1/4 NW 1/4 Sec 4 T 29 N. R 2E W.M.
 Bearing and distance from section or subdivision corner 1600' W C-UT SEC 4 COR. SOUTHW

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒
 Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
 New well ☒ Method: Dug ☐ Bored ☐
 Deepened ☐ Cable ☐ Driven ☐
 Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
 Drilled 280 ft. Depth of completed well 280 ft.

(6) CONSTRUCTION DETAILS:
 Casing installed: 6 " Diam. from 0 ft. to 270 ft.
 Threaded ☐ " Diam. from ft. to ft.
 Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☐
 Type of perforator used
 SIZE of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

Screens: Yes ☒ No ☐ COOK
 Manufacturer's Name
 Type Model No
 Diam. 6 Slot size 10 from 270 ft. to 280 ft.
 Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☐ Size of gravel:
 Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.
 Material used in seal BEAUFORT
 Did any strata contain unusable water? Yes ☐ No ☒
 Type of water? Depth of strata
 Method of sealing strata off

(7) PUMP: Manufacturer's Name
 Type: HP.

(8) WATER LEVELS: Land-surface elevation above mean sea level 220 ft.
 Static level 210 ft. below top of well Date
 Artesian pressure lbs. per square inch Date
 Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.

.....

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
.....

Date of test 9/11/82
 Bailer test 10 gal./min. with 5 ft. drawdown after 1 1/2 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	1
SAND + CLAY GRAY	1	65
SAND + GRAY	65	200
CLAY GRAY	200	240
SAND W.W. GRAY	240	280

Work started 9/1/82, 19..... Completed 9/12/82, 19.....

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W DRILLING (Person, firm, or corporation) (Type or print)

Address 4087 E. PRUK. RD.

[Signed] [Signature] (Well Driller)

License No. 285 Date 9/12/82